



Type Examination

No. CE 67600 Issue 3

Issued to:

Elster Jeavons Limited
Lower Church Lane
Tipton
West Midlands
DY4 7PH
United Kingdom



In respect of:

J125 & J1253 Pressure Regulators as per technical file J125 & J1253 issue 0.

On the basis of our examination under the requirements of Council Directive 97/23/EC Module B of the Pressure Equipment Directive, as transposed into UK law by the Pressure Equipment Regulations SI 1999 2001.

For and on behalf of the British Standards Institution, a Notified Body for the above Directive (Notified Body Number 0086):

Alastair Trivett, Managing Director, BSI Product Services – Global

First Issued: 9 Jul 2002

Date: 21 Dec 2006

Page: 1 of 2

Any modifications to the design of this product will invalidate this EC-Type Examination Certificate and the BSI Notified Body, Number 0086 must be informed without delay

Type Examination

No: CE 67600 Issue 3

ADDITIONAL INFORMATION

LIMITATIONS OF CERTIFICATE VALIDITY

J125 models

PS = 0 to 8.6 bar g

TS = -20 to +80°C for DN 19, 25 & 40 (3/4", 1" & 1.1/2" models)

TS = -20 to +70°C for DN 50 (2" model.)

J1253 models

PS = 0 to 8.6 bar g

TS = -20 to +80°C for DN 19 (3/4" models)

First Issued: 9 Jul 2002

Date: 21 Dec 2006

Page: 2 of 2

Any modifications to the design of this product will invalidate this EC-Type Certificate and the BSI Notified Body, Number 0086 must be informed without delay